



SHRUB, TREE AND GROUNDCOVER PLANTING DETAIL

UPPERMOST ROOT SHALL BE NO MORE THAN 1" (IN) BELOW SOIL SURFACE BACKFILL WITH SOIL REMOVED FROM THE HOLE. COMPACT LIGHTLY IN INCREMENTAL LIFTS. BREAK UP ROOTBALL OF CONTAINER PLANTS, INCLUDING PLUGS ~ SPREAD ROOTS **EXISTING SOIL** 3 TIMES THE ROOT SPREAD

## **EMERGENT PLANTING DETAIL**



TUBER OR RHIZOME PLANTING DETAIL



SHRUB, TREE AND GROUNDCOVER SLOPE PLANTING DETAIL

#### NOTES:

1.) See Standard Specification Section 8-02.3(8) and 9-14.7 for additional

ENSURE TREE IS STRAIGHT AND VERTICAL

CHAINLOCK TREE TIES 1/2" MAX WIDTH SECURE TO WOOD STAKE WITH STAPLE

2" X 2" WOOD STAKE (LENGTH AS REQUIRED) DO NOT PENETRATE ROOTBALL, SET STAKES PARALLEL TO PREVAILING WIND

UPPERMOST ROOT SHALL BE NO MORE THAN 1" BELOW SOIL SURFACE

MULCH & COMPOST TO SPECIFIED DEPTH -FEATHER TO BASE OF PLANT

REMOVE ALL MATERIAL AROUND (B&B) ROOTBALL, LOOSEN SIDES OF ROOT MASS CUT AND SPREAD CIRCLING ROOTS

MOUND SOIL TO FORM WATERING WELL AT OUTER EDGE OF PLANTING HOLE

BACKFILL WITH SOIL REMOVED FROM THE HOLE ~ COMPACT LIGHTLY IN INCREMENTAL LIFTS

SIDES OF HOLE SHALL BE ROUGH AND

SET ROOTBALL ON NATIVE, UNDISTURBED

**EXISTING SOIL** 

# STREET TREE PLANTING DETAIL

3 TIMES THE ROOT SPREAD

ENSURE PLANT IS STRAIGHT AND VERTICAL

UPPERMOST ROOT SHALL BE NO MORE THAN 1" (IN) BELOW SOIL SURFACE

MULCH & COMPOST TO SPECIFIED DEPTH ~ FEATHER TO BASE OF PLANT

MOUND SOIL TO FORM WATERING WELL AT DRIPLINE OF EACH PLANT

BACKFILL WITH SOIL REMOVED FROM THE HOLE, COMPACT LIGHTLY IN INCREMENTAL

EXISTING SOIL



May 31, 2024

## TREE, SHRUB AND GROUNDCOVER PLANTING DETAILS

## STANDARD PLAN H-10.10-01

SHEET 1 OF 1 SHEET



STATE DESIGN ENGINEER

Washington State Department of Transportation